

Map ID
Direction
Distance
Elevation

MAP FINDINGS

Site

Database(s)

EDR ID Number
EPA ID Number

1049
NE
> 1
1.373 mi.
7250 ft.

VAULT #6235
CONEY ISLAND AVENUE & GRAVESEND NECK ROAD
BROOKLYN, NY

NY Spills S108058638
N/A

Relative:
Higher

Actual:
13 ft.

SPILLS:

Name: VAULT #6235
Address: CONEY ISLAND AVENUE & GRAVESEND NECK ROAD
City,State,Zip: BROOKLYN, NY
Spill Number/Closed Date: 0604343 / 2006-11-15
Facility ID: 0604343
Facility Type: ER
DER Facility ID: 317301
Site ID: 367294
DEC Region: 2
Spill Cause: Equipment Failure
Spill Class: C4
SWIS: 2401
Spill Date: 2006-07-18
Investigator: GDBREEN
Referred To: Not reported
Reported to Dept: 2006-07-18
CID: 71
Water Affected: Not reported
Spill Source: Commercial/Industrial
Spill Notifier: Responsible Party
Cleanup Ceased: Not reported
Cleanup Meets Std: False
Last Inspection: Not reported
Recommended Penalty: False
UST Trust: False
Remediation Phase: 0
Date Entered In Computer: 2006-07-19
Spill Record Last Update: 2006-11-15
Spiller Name: Not reported
Spiller Company: Not reported
Spiller Address: Not reported
Spiller Company: Not reported
Contact Name: ERT DESK
DEC Memo: "11/15/06 - See e-docs for Con Ed report detailing cleanup and closure. 201249. see eDocs"
Remarks: "OVERHEATED TRANSFORMER. CON ED REF #201249"

All Materials:

Site ID: 367294
Operable Unit ID: 1125211
Operable Unit: 01
Material ID: 2114733
Material Code: 0541A
Material Name: dielectric fluid
Case No.: Not reported
Material FA: Petroleum
Quantity: 5.00
Units: G
Recovered: .00
Oxygenate: Not reported